

Missouri Department of Natural Resources
STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO-0039748

Owner: Trenton Municipal Utilities
Address: 1100 Main Street, Trenton, MO 64683

Continuing Authority: Same as above
Address: Same as above

Facility Name: Trenton Municipal Utilities Wastewater Treatment Facility
Address: 98 Southwest Lane, Trenton, MO 64683

Legal Description: Outfalls #001 & 002, NW ¼, NW ¼, Sec. 27, T61N, R24W, Grundy County
Outfall #003, NW ¼, NW ¼, Sec. 17, T61N, R24W, Grundy County

Receiving Stream: Outfalls #001 & 002 - Muddy Creek (P), Outfall #003 Tributary to Thompson R. (U)
First Classified Stream and ID: Outfalls #001 & 002 - Muddy Creek (P) (00557)
Outfall #003 - Thompson River (P) (00549)

USGS Basin & Sub-watershed No.: Outfalls #001 & 002-(10280102 - 170003), Outfall #003-(10280102-190004)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

(See Page Two)

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

December 30, 2005 June 2, 2006
Effective Date Revised Date


Doyle Childers, Director, Department of Natural Resources
Executive Secretary, Clean Water Commission

December 29, 2010
Expiration Date
MO 780-0041 (10-93)

Edward Galbraith, Director of Staff, Clean Water Commission

FACILITY DESCRIPTION

Outfall #001 - POTW - 92-500 - SIC #4952

Extended aeration treatment plant with aerobic digesters and influent pump station/sludge is land applied.

Design population equivalent is 60,000.

Design flow is 1.9 MGD.

Actual flow is 1.4 MGD.

Design sludge production is 1,080 dry tons/year.

Actual sludge production is 100 dry tons/year.

Outfall #002 - POTW - 92-500 - SIC #4952

Two cell lagoon (peak flow stormwater clarifier)/sludge is retained in lagoon.

Design flow is 0.77 MGD.

Actual flow is dependent upon peak flow stormwater conditions.

Outfall #003 - POTW - 92-500 - SIC #4952

Peak flow retention basin. All flows from this basin will be treated at main WWTF and flow through Outfall #001.

A. INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS					PAGE NUMBER 3 of 9	
					PERMIT NUMBER MO-0039748	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The interim effluent limitations shall become effective upon issuance and remain in effect until December 30, 2008. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	INTERIM EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	MGD	*		*	once/day	24 hr. total
Biochemical Oxygen Demand ₅ **	mg/L		45	30	once/week	24 hr. composite
Total Suspended Solids**	mg/L		45	30	once/week	24 hr. composite
pH – Units	SU	***		***	once/week	grab
Ammonia as N (May 1 – Oct 31)	mg/L	*		*	once/week	grab
Ammonia as N (Nov 1 – Apr 30)	mg/L	*		*	once/week	grab
Oil and Grease	mg/L	*		*	once/week	grab
Copper, Total Recoverable	mg/L	*		*	once/quarter	24 hr. composite
Lead, Total Recoverable	mg/L	*		*	once/quarter	24 hr. composite
Zinc, Total Recoverable	mg/L	*		*	once/quarter	24 hr. composite
Chromium, Total Recoverable	mg/L	*		*	once/quarter	24 hr. composite
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> FIRST REPORT IS DUE <u>February 28, 2006</u> .						
Whole Effluent Toxicity (WET) Test	% Survival	(See Special Conditions)			once/year in June	24 hr. composite
MONITORING REPORTS SHALL BE SUBMITTED <u>ANNUALLY</u> ; THE FIRST REPORT IS DUE <u>October 28, 2006</u> .						
<u>Outfalls #002 & 003 (Note 1)</u>						
Flow	MGD	*		*	once/day	24hr estimate
Biochemical Oxygen Demand ₅	mg/L		45		once/week	grab
Total Suspended Solids	mg/L		45		once/week	grab
pH	SU	***		***	once/week	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> FIRST REPORT IS DUE <u>February 28, 2006</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
B. STANDARD CONDITIONS						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I, II, & III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- * Monitoring requirement only.
- ** This facility is required to meet a removal efficiency of 85% or more.
- *** pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.

Note 1 – Outfall #003 is a holding basin and is not expected to discharge. Limits are for emergency discharge only. Report as no discharge on your monthly report.

A. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS					PAGE NUMBER 4 of 9	
					PERMIT NUMBER MO-0039748	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective December 31, 2008, and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Outfall #001						
Flow	MGD	*		*	once/day	24 hr. total
Biochemical Oxygen Demand ₅ **	mg/L		45	30	once/week	24 hr. composite
Total Suspended Solids**	mg/L		45	30	once/week	24 hr. composite
pH – Units	SU	***		***	once/week	grab
Ammonia as N (May 1 – Oct 31)	mg/L	5.3		2.6	once/week	grab
Ammonia as N (Nov 1 – Apr 30)	mg/L	7.5		3.7	once/week	grab
Oil and Grease	mg/L	15		10	once/week	grab
Copper, Total Recoverable	mg/L	*		*	once/quarter	24 hr. composite
Lead, Total Recoverable	mg/L	*		*	once/quarter	24 hr. composite
Zinc, Total Recoverable	mg/L	*		*	once/quarter	24 hr. composite
Chromium, Total Recoverable	mg/L	*		*	once/quarter	24 hr. composite
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> FIRST REPORT IS DUE <u>February 28, 2009</u> .						
Whole Effluent Toxicity (WET) Test	% Survival	(See Special Conditions)			once/year in June	24 hr. composite
MONITORING REPORTS SHALL BE SUBMITTED <u>ANNUALLY</u> ; THE FIRST REPORT IS DUE <u>October 28, 2009</u> .						
Outfalls #002 & 003 (Note 1)						
Flow	MGD	*		*	once/day	24hr estimate
Biochemical Oxygen Demand ₅	mg/L		45		once/week	grab
Total Suspended Solids	mg/L		45		once/week	grab
pH	SU	***		***	once/week	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> FIRST REPORT IS DUE <u>February 28, 2009</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
B. STANDARD CONDITIONS						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I, II, & III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- * Monitoring requirement only.
- ** This facility is required to meet a removal efficiency of 85% or more.
- *** pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.

Note 1 – Outfall #003 is a holding basin and is not expected to discharge. Limits are for emergency discharge only. Report as no discharge on your monthly report.

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
 - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.
2. All outfalls must be clearly marked in the field.
3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.
4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
 - (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
 - (c) That the effluent limit established in part A of the permit will be exceeded.
5. Report as no-discharge when a discharge does not occur during the report period.
 6. Water Quality Standards
 - (a) Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
 - (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (5) There shall be no significant human health hazard from incidental contact with the water;
 - (6) There shall be no acute toxicity to livestock or wildlife watering;
 - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

C. SPECIAL CONDITIONS (continued)

7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities
 - (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
 - (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.
8. If, upon the completion of the Department's protocol to calculate ammonia limits under sections 10 CSR 20-7.031(1)(G)(6) and 10 CSR 20-7.031(4), the permittee's study in accordance with said protocol suggests that the final ammonia limits included in this permit are not appropriate or otherwise not supported by scientific data, the permittee may request reopening this permit to include revised ammonia limits consistent with the results of the study. If the Department concurs, the ammonia limits shall be revised.
9. Whole Effluent Toxicity (WET) tests shall be conducted as follows:

SUMMARY OF WET TESTING FOR THIS PERMIT				
OUTFALL	A.E.C. %	FREQUENCY	SAMPLE TYPE	MONTH
#001	100	Annually	24 hr composite	June

- (a) Test Schedule and Follow-Up Requirements
 - (1) Perform a SINGLE-dilution test in the months and at the frequency specified above. For tests which are successfully passed, submit test results USING THE DEPARTMENT'S WET TEST REPORT FORM #MO-780-1899 along with complete copies of the test reports as received from the laboratory, including copies of chain-of-custody forms within 30 calendar days of availability to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102. If the effluent passes the test, do not repeat the test until the next test period.
 - (a) For discharges of stormwater, samples shall be collected within three hours from when discharge first occurs.
 - (b) Samples submitted for analysis of stormwater discharges shall be collected as a grab.
 - (c) For discharges of non-stormwater, samples shall be collected only when precipitation has not occurred for a period of forty-eight hours prior to sample collection. In no event shall sample collection occur simultaneously with the occurrence of precipitation.
 - (d) A twenty-four hour composite sample shall be submitted for analysis of non-stormwater discharges.
 - (e) Upstream receiving water samples, where required, shall be collected upstream from any influence of the effluent where downstream flow is clearly evident.
 - (f) Samples submitted for analysis of upstream receiving water may be collected as either a grab or twenty-four-hour composite as appropriate to the nature of the discharge.
 - (g) Chemical and physical analysis of the upstream control and effluent sample shall occur immediately upon being received by the laboratory, prior to any manipulation of the effluent sample beyond preservation methods consistent with federal guidelines for WET testing that are required to stabilize the sample during shipping.
 - (h) Any and all chemical or physical analysis of the effluent sample performed in conjunction with the WET test shall be performed at the 100% Effluent concentration in addition to analyses performed upon any other effluent concentration.
 - (i) All chemical analyses included in the Missouri Department of Natural Resources WET test report form #MO-780-1899 shall be performed and results shall be recorded in the appropriate field of the report form.
 - (j) Where flow-weighted composite sample is required for analysis, the samples shall be composited at the laboratory where the test is to be performed.
 - (k) Where in stream testing is required downstream from the discharge, sample collection shall occur immediately below the established Zone of Initial Dilution in conjunction with or immediately following a release or discharge.

C. SPECIAL CONDITIONS (continued)

- (l) Samples submitted for analysis of downstream receiving water may be collected as either a grab or twenty-four-hour composite as appropriate to the nature of the discharge.
 - (m) All instream samples, including downstream samples, shall be tested for toxicity at the 100% concentration in addition to any other assigned AEC for in-stream samples.
 - (2) All failing test results along with complete copies of the test reports as received from the laboratory, INCLUDING THOSE TESTS CONDUCTED UNDER CONDITION (3) BELOW, shall be reported to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the availability of the results.
 - (3) If the effluent fails the test, a multiple dilution test shall be performed within 30 calendar days and biweekly thereafter, until one of the following conditions are met:
 - (a) THREE CONSECUTIVE MULTIPLE-DILUTION TESTS PASS. No further tests need to be performed until next regularly scheduled test period.
 - (b) A TOTAL OF THREE MULTIPLE-DILUTION TESTS FAIL.
 - (4) Failure of at least three multiple-dilution tests during any period of accelerated monitoring violates the permit narrative requirement for aquatic life protection.
 - (5) The permittee shall submit a CONCISE summary of all test results for the test series to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the third failed test.
 - (6) Additionally, the following shall apply upon failure of the third MULTIPLE DILUTION test: A toxicity identification evaluation (TIE) or toxicity reduction evaluation (TRE) is automatically triggered. The permittee shall contact THE WATER PROTECTION PROGRAM within 14 calendar days from availability of the test results to ascertain as to whether a TIE or TRE is appropriate. The permittee shall submit a plan for conducting a TIE or TRE to the WATER PROTECTION PROGRAM within 60 calendar days of the date of DNR's direction to perform either a TIE or TRE. This plan must be approved by DNR before the TIE or TRE is begun. A schedule for completing the TIE or TRE shall be established in the plan approval.
 - (7) Upon DNR's approval, the TIE/TRE schedule may be modified if toxicity is intermittent during the TIE/TRE investigations. A revised WET test schedule may be established by DNR for this period.
 - (8) If a previously completed TIE has clearly identified the cause of toxicity, additional TIEs will not be required as long as effluent characteristics remain essentially unchanged and the permittee is proceeding according to a DNR approved schedule to complete a TRE and reduce toxicity. Regularly scheduled WET testing as required in the permit, without the follow-up requirements, will be required during this period.
 - (9) When WET test sampling is required to run over one DMR period, each DMR report shall contain a copy of the Department's WET test report form that was generated during the reporting period.
 - (10) Submit a concise summary in tabular format of all test results with the annual report.
- (b) PASS/FAIL procedure and effluent limitations:
- (1) To pass a single-dilution test, mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level; $p = 0.05$) than that observed in the upstream receiving-water control sample. Where upstream receiving water is not available mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level; $p = 0.05$) than that observed in the laboratory control. The appropriate statistical tests of significance shall be consistent with the most current edition of METHODS FOR MEASURING THE ACUTE TOXICITY OF EFFLUENTS AND RECEIVING WATERS TO FRESHWATER AND MARINE ORGANISMS or other Federal guidelines as appropriate or required.
 - (2) To pass a multiple-dilution test:
 - (a) For facilities with a computed percent effluent at the edge of the zone of initial dilution, Allowable Effluent Concentration (AEC), OF 30% OR LESS THE AEC must be less than three-tenths (0.3) of the LC_{50} concentration for the most sensitive of the test organisms; **OR**,
 - (b) For facilities with an AEC greater than 30% the LC_{50} concentration must be greater than 100%; **AND**,

C. SPECIAL CONDITIONS (continued)

- (c) all effluent concentrations equal to or less than the AEC must be nontoxic. Mortality observed in all effluent concentrations equal to or less than the AEC shall not be significantly different (at the 95% confidence level; $p = 0.05$) than that observed in the upstream receiving-water control sample. Where upstream receiving water is not available mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level; $p = 0.05$) than that observed in the laboratory control. The appropriate statistical tests of significance shall be consistent with the most current edition of METHODS FOR MEASURING THE ACUTE TOXICITY OF EFFLUENTS AND RECEIVING WATERS TO FRESHWATER AND MARINE ORGANISMS or other federal guidelines as appropriate or required. Failure of one multiple-dilution test may be considered an effluent limit violation.

(c) Test Conditions

- (1) Test Type: Acute Static non-renewal
- (2) Test species: Ceriodaphnia dubia and Pimephales promelas (fathead minnow). Organisms used in WET testing shall come from cultures reared for the purpose of conducting toxicity tests and cultured in a manner consistent with the most current USEPA guidelines. All test animals shall be cultured as described in the most current edition of METHODS FOR MEASURING THE ACUTE TOXICITY OF EFFLUENTS AND RECEIVING WATERS TO FRESHWATER AND MARINE ORGANISMS.
- (3) Test period: 48 hours at the "Acceptable Effluent Concentration" (AEC) specified above.
- (4) When dilutions are required, upstream receiving stream water shall be used as dilution water. If upstream water is unavailable or if mortality in the upstream water exceeds 10%, "reconstituted" water will be used as dilution water. Procedures for generating reconstituted water will be supplied by the MDNR upon request.
- (5) Single-dilution tests will be run with:
 - (a) Effluent at the AEC concentration;
 - (b) 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
 - (c) reconstituted water.
- (6) Multiple-dilution tests will be run with:
 - (a) 100%, 50%, 25%, 12.5%, and 6.25% effluent, unless the AEC is less than 25% effluent, in which case dilutions will be 4 times the AEC, two times the AEC, AEC, 1/2 AEC and 1/4 AEC;
 - (b) 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
 - (c) reconstituted water.
- (7) If reconstituted-water control mortality for a test species exceeds 10%, the entire test will be rerun.
- (8) If upstream control mortality exceeds 10%, the entire test will be rerun using reconstituted water as the dilutant.

D. SCHEDULE OF COMPLIANCE

The permittee shall demonstrate compliance with the Final Effluent Limitations for Ammonia as N, as listed in Part A of this permit, or submit a completed application for a construction permit and fee along with one copy each of engineering report, plans and specifications, prepared by a professional engineer registered in the State of Missouri, by December 1, 2006.

The permittee shall respond within fifteen(15) calendar days of any request for additional information or changes in the engineering report, plans or specifications, respond, and submit engineering modifications,if necessary,to the department and obtain a construction permit by December 1, 2007.

Within fifteen (15) days of completion of construction, submit a Statement of Work Completed form, signed, sealed, and dated by a professional engineer, registered in the State of Missouri, certifying that the project has been completed substantially in accordance with the approved plans and specifications. In addition to the Statement of Work Completed, submit an application for a Missouri State Operating Permit modification, complete with the appropriate modification fee, to the Missouri Department of Natural Resources, Water Protection Program, P.O. Box 176, Jefferson City, MO 65102.

Permittee shall complete construction and meet the Final Effluent Limitations for Ammonia as N by December 31, 2008.

SUMMARY OF TEST METHODOLOGY FOR WHOLE-EFFLUENT TOXICITY TESTS

Whole-effluent-toxicity test required in NPDES permits shall use the following test conditions when performing single or multiple dilution methods. Any future changes in methodology will be supplied to the permittee by the Missouri Department of Natural Resources (MDNR). Unless more stringent methods are specified by the DNR, the procedures shall be consistent with the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms.

Test conditions for Ceriodaphnia dubia:

Test duration:	48 h
Temperature:	25 ± 1°C Temperatures shall not deviate by more than 3°C during the test.
Light Quality:	Ambient laboratory illumination
Photoperiod:	16 h light, 8 h dark
Size of test vessel:	30 mL (minimum)
Volume of test solution:	15 mL (minimum)
Age of test organisms:	<24 h old
No. of animals/test vessel:	5
No. of replicates/concentration:	4
No. of organisms/concentration:	20 (minimum)
Feeding regime:	None (feed prior to test)
Aeration:	None
Dilution water:	Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness.
Endpoint:	Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at $p \leq 0.05$)
Test acceptability criterion:	90% or greater survival in controls

Test conditions for Pimephales promelas:

Test duration:	48 h
Temperature:	25 ± 1°C Temperatures shall not deviate by more than 3°C during the test.
Light Quality:	Ambient laboratory illumination
Photoperiod:	16 h light/ 8 h dark
Size of test vessel:	250 mL (minimum)
Volume of test solution:	200 mL (minimum)
Age of test organisms:	1-14 days (all same age)
No. of animals/test vessel:	10
No. of replicates/concentration:	4 (minimum) single dilution method 2 (minimum) multiple dilution method
No. of organisms/concentration:	40 (minimum) single dilution method 20 (minimum) multiple dilution method
Feeding regime:	None (feed prior to test)
Aeration:	None, unless DO concentration falls below 4.0 mg/L; rate should not exceed 100 bubbles/min.
Dilution water:	Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness.
Endpoint:	Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at $p \leq 0.05$)
Test Acceptability criterion:	90% or greater survival in controls